

燃油（气）燃烧器型式试验证书

Type Testing Certificate for Oil/Gas Burner

证书编号/Certificate No. : TSX B1000120190559

制 造 单 位
Manufacturer Vitotherm BV

单 位 地 址
Manufacturer Address Overgauwseweg 8,2641 NE,Pijnacker,The Netherlands

燃 烧 器 名 称
Name of Burner Vitotherm

燃 烧 器 型 号
Model of Burner VGOIs-350

燃 烧 器 类 别
Classification of Burner 油气两用燃烧器

试 验 报 告 书 编 号
Type Testing Report No. 19X0313-XR01

经试验，确认符合《燃油（气）燃烧器安全技术规则》
的规定，主要配件见附件。 / Has been examined to be in accordance
with the *Safety Technical Regulation for Oil and Gas Burners*. The list of main
accessories is attached overleaf.

中国特种设备检测研究院
China Special Equipment Inspection and Research Institute

发证日期 / Issue Date: 2019年09月06日

注/note:

- 1.本证书有效期4年 / This certificate is valid for four years after the issue date.
- 2.本证书是对所明确覆盖范围内设备型式的确认，仅对样品本身试验时的合格与否负责 / This certificate is a type approval for the specified burner and the result is only responsible for the testing sample.
- 3.证书持有者有责任保证产品符合标准规定和保证产品与型式试验样品的一致性 / The certificate holder shall take responsibilities to ensure that the products can satisfy the relevant regulations, and keep the products conform to the testing sample.

附件：主要配件表 / attachment: list of main accessories

配件名称	型号	主要参数	制造单位名称
程序控制器	ETAMATIC OEM S	115-230V/50Hz	LAMTEC
点火变压器	EBI4	15kV,40mA	Danfoss
火焰监测器	QRA2	/	SIEMENS
安全切断阀 (燃气)	VGD20.503	DN50,Pmax60kPa	SIEMENS
安全切断阀 (燃油)	E321H25	15mm, 40bar	parker
油泵	SMG-1628-D-4-10	700 l/h,Pmax30bar	HP
伺服马达	ACTUATOR20Nm (气/风)	230VAC/50Hz,60SECONDS/90° , IP54	LAMTEC
	ACTUATOR20Nm (油)	230VAC/50Hz,40SECONDS/90° , IP54	LAMTEC
电源	/	220/380V,50Hz	/

说明：该燃烧器采用 FGR 技术。